

CERTIFICATES & TEST COMPLIANCE

TEST REPORT

SABS

FRANKE KITCHEN SYSTEMS
Att: Mr. C. Rothman
 P.O Box 72395
 South Coast Road
 Mobeni
 4060

Your ref : Order No: 287072
 Our ref : ZH 223 a
 Enquiries : Karel Deist
 Tel : 012 428-7029
 Page : 1 of 5
 Date : 02-11 -2005

TESTING TO SABS 1733:2002

0 SUMMARY

A full specification test was performed on the Franke Kitchens prison toilet pan submitted. This toilet pan passed these tests. Refer to clause 4 for the detail of the test performed and to clause 9 for a summary of the results.

1 DESCRIPTION OF SAMPLE

The low flushing toilet pan was submitted by Mr C. Rothman of and on behalf the company Franke Kitchen Systems.

<u>Sample No.</u>	<u>Quantity</u>	<u>Sample Description</u>
ZH 223 a	1	Franke Kitchens stainless steel prison toilet pan

2. REPORT CONDITIONS

The contents of this test report refers to the sample/s detailed above and does not infer that the above samples (or any other similar samples) are SABS approved for quality and/or performance.

In the instance where this report is used to verify compliance with the JASWIC Acceptance Scheme, the validity of the test reports shall not exceed a period of one (1) year.

3 SAMPLE SUBMITTED

The prison toilet pan was received in a good condition and was suitable for testing.

Date sample received : 31 - 10 - 2006
 Date test started : 01 - 11 - 2006
 Date test completed : 02 - 11 - 2006

4 TEST REQUESTED

To test the Franke Kitchens stainless steel prison toilet pan submitted for full compliance with the requirements of: SABS 1733:2002 and in addition, with a 6 litre concealed cistern and with the WCLP flush valve set for a 6 litre flush.

1 Dr Lategan Road Groenkloof, Private Bag X191 Pretoria 0001, Tel: +27 (012) 428-7911, Fax: +27 (012) 344-1568.

This test was performed by SABS Commercial (Pty) Ltd.

This report and the test results relate only to the specific sample(s) identified herein. They do not imply SABS approval of the quality and/or performance of the item(s) in question and the test results do not apply to any similar item that has not been tested.
 (Refer also to the complete conditions printed on the back of this page.)