

# SPECIFICATION NO: RD234

NEW WORK/REPAIN	T: REPAIN	REPAINT – INTERIOR										
SUBSTRATE:	LAMDA	LAMDA BOARD (JOINT FILLING AND PAINTING)										
PAINT FINISH:		Plascon Polvin Super Acrylic PRODUCT CODE: <b>EPL</b> (Smooth finish – water based, superior matt acrylic, durable)										
COLOUR:		White and standard colours as per colour card, plus Plascon colour system and other fan decks.										
ENVIRONMENT:	The Maintenance Cycle is a guide but can vary due to micro limate changes identified on the site which will affect the longevity of the coating system											
	As per ISO 12944-2:1998		Maint	Maintenance Cycle (Years)								
	C1 -	Inland		7	. ,							
	C3 -	Industrial		7								
	C5 -	Coastal / Marine		7								
Plascon Coating	Application	Spreading	WET/DET um	Reducer/	Overcoating	Technical	TV					

Plascon Coating System	Application Method	Spreading Rate m²/&	WFT/DFT μm (min & max)	Reducer/ Cleaner	Overcoating time h @ 23 °C	Technical Data Sheet No	TVOC g/୧
Spot Sealer	B, R or S	@15 μm	WFT 125-167	Mineral	16	CVI 14	
Plascon Bonding		Theo: 8	DFT 15-20	Turps			
Liquid		Prac:		(AZH 1)			
(CVI 14)		depends on					
(Transparent		porosity					
Green)							
Joint	Trowel	0.343 kg/	2 mm	Water	24	TER 1120	
Terraco		linear metre					
Handycoat Flex							
(TER 1120)							
1 <sup>st</sup> Finishing Coat	B, R or S	@ 30 μm	WFT 74-103	Water	1	EPL	< 16 white,
Plascon Polvin		Theo: 11.3	DFT 25-35				pastel, deep
Super Acrylic		Prac: 6.3					&
(EPL/TAP)							transparent
							tinted
2 <sup>nd</sup> Finishing Coat	B, R or S	@ 30 μm	WFT 74-103	Water	1	EPL	< 16 white,
Plascon Polvin		Theo: 11.3	DFT 25-35				pastel, deep
Super Acrylic		Prac: 6.3					&
(EPL/TAP)							transparent
							tinted



-



# SPECIFICATION NO: RD234

# SURFACE PREPARATION:

 After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

### **APPLICATION:**

#### **Primer Coat**

A Spot prime bare and repaired areas with Plascon Bonding Liquid (CVI 14). Allow 16 hours to dry.

#### Joints

- A Rake and refill compromised joints with Terraco Handycoat Flex (TER 1120) using a spatula. Allow to dry for 24 hours.
- Refill joint with Terraco Handycoat Flex (TER1120) using a spatula tooling into joint to fill the shrinkage that has
  occurred.

# **Finishing Coats**

 Apply two full coats of Plascon Polvin Super Acrylic (EPL/TAP) to achieve complete obliteration, allowing 1 hour drying between coats.

# TABLE REFERENCES:

- A Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only - actual must be determined by user.
- Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

