

SPECIFICATION NO: RD306r

COLOUR:

NEW WORK/REPAINT: REPAINT – INTERIOR / EXTERIOR

SUBSTRATE: Metals - Galvanized Iron

PAINT FINISH: Plascon Waterbased Velvaglo PRODUCT CODE: VLW

White plus Plascon colour system and other fan decks.

(Smooth finish – water based, superior medium

satin finish waterbased enamel)

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on

the site which will affect the longevity of the coating system

As per ISO 12944-2:1998 Maintenance Cycle (Years)

 C1 Inland
 7

 C3 Industrial
 5

 C5 Coastal / Marine
 5

Plascon Coating System	Application Method	Spreading Rate	WFT/DFT μm	Reducer/ Cleaner	Overcoating time	Technical Data Sheet	TVOC g/ℓ
		m²/ℓ	(min & max)		h @ 23 °C	No	
Spot Primer	B, R or S	@ 55 μm	WFT 135-	Water	WB topcoat:	MWP 1	26
Plascon Metalcare		Theo: 6.7	162		8		
Metal WB Primer		Prac: 4.4	DFT 50-60		SB topcoat:		
(MWP 1)					16		
1 st Finishing Coat	B, R or S	@ 35 μm	WFT 88-118	Water	4	VLW	46-50 white,
Plascon		Theo: 9.7	DFT 30-40				pastel tinted
Waterbased		Prac: 5.5					< 53-60 deep
Velvaglo							&
(VLW/TVW)							transparent
							bases tinted
2 nd Finishing Coat	B, R or S	@ 35 μm	WFT 88-118	Water	4	VLW	46-50 white,
Plascon		Theo: 9.7	DFT 30-40				pastel tinted
Waterbased		Prac: 5.5					< 53-60 deep
Velvaglo							&
(VLW/TVW)							transparent
							bases tinted



Revision Date: January 2016



SPECIFICATION NO: RD306r

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

^ Spot prime bare and repaired areas with Plascon Metalcare Metal WB Primer (MWP 1). Allow 8 hours to dry before overcoating with a waterbased topcoat or allow 16 hours when overcoating with a solvent based topcoat.

Finishing Coats

Apply two full coats of Plascon Waterbased Velvaglo (VLW/TVW) to achieve complete obliteration, allowing 4 hours drying between coats.

NB: if white is used, three coats might be necessary to achieve obliteration.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

