

SPECIFICATION NO: RD302t

NEW WORK/REPAINT: REPAINT – INTERIOR / EXTERIOR

SUBSTRATE: Metals - Galvanized Iron

PAINT FINISH: Plascon Plascothane Polyurethane Enamel PRODUCT CODE: **UP**

(Smooth finish – solvent based, tough, fast drying 2-pack

polyurethane-acrylic gloss) 9:1 Mixing ratio by volume

COLOUR: White

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on the site which will affect the longevity of the coating system

As per ISO 12944-2:1998 Maintenance Cycle (Years)

 C1 Inland
 8

 C3 Industrial
 7

 C5 Coastal / Marine
 7

Plascon Coating	Application	Spreading	WFT/DFT	Reducer/	Overcoating	Technical	TVOC
System	Method	Rate	μm	Cleaner	time	Data Sheet	g/€
		m²/ℓ	(min & max)		h @ 23 °C	No	
Spot Primer	B or S	@ 25 μm	WFT 83-125	GP	4	AW 255	618
Plascon Epiwash		Theo: 9.6	DFT 20-30	Ероху	2 weeks		
Strontium		Prac: 5.1		Reducer	max		
Chromate Primer				(EPT 1)			
(AW 255/KAT 508)				Or			
Mixing ratio 1:1				Epiwash			
by volume				Thinner			
				(TH 128)			
1st Finishing Coat	S	@ 30 μm	WFT 60-119	Polyure-	30 mins min	UP	523 white
Plascothane 9:1		Theo: 14	DFT 25-50	thane	48 max		610 colours &
Polyurethane		Prac: 7.7		Acrylic			toners
Enamel				Thinner			
(UP/KAT 518)				(AW 260)			
Mixing ratio 9:1							
by volume							
2 nd Finishing Coat	S	@ 30 μm	WFT 60-119	Polyure-	30 mins min	UP	523 white
Plascothane 9:1		Theo: 14	DFT 25-50	thane	48 max		610 colours &
Polyurethane		Prac: 7.7		Acrylic			toners
Enamel				Thinner			
(UP/KAT 518)				(AW 260)			
Mixing ratio 9:1							
by volume							



Revision Date: January 2016



SPECIFICATION NO: RD302t

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

^ Spot prime bare and repaired areas with Plascon Epiwash Strontium Chromate Primer (AW 255). Allow minimum 4 hours to dry.

Finishing Coats

Mix the base and hardener thoroughly, in the ratio of 9:1 by volume.

Apply two full coats of Plascon Plascothane Polyurethane Enamel (UP) to achieve complete obliteration, allowing 30 minutes drying between coats.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

