

SPECIFICATION NO: RD107t

NEW WORK/REPAINT: REPAINT – INTERIOR/EXTERIOR

SUBSTRATE: Masonry (Cement Plaster, Concrete, Off-Shutter, Pre-Cast, Unglazed Brickwork) and Fibre-

Cement Board

PAINT FINISH: Professional Superior Matt PRODUCT CODE: PEM 950

Premium quality ultra matt

Silicone enhanced acrylic technology for improve water resistance, dirt repellence &

Mould resistance Excellent washability

No odour

COLOUR: Plascon colour system.

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro climate changes identified on

the site which will affect the longevity of the coating system

As per ISO 12944-2:1998 Maintenance Cycle (Years)

 C1 Inland
 7

 C3 Industrial
 7

 C5 Coastal / Marine
 7

| Plascon Coating System | Application Method | Spreading Rate m²/€ | WFT/DFT μm (min & max) | Reducer/ Cleaner | Overcoating time h @ 23 °C | Technical Data Sheet No | TVOC g/e |
|--------------------------------|-----------------------|---------------------------|---------------------------|---------------------|----------------------------------|-------------------------------|-------------|
| Spot Primer | B, R or S | @ 40 μm | WFT 109-129 | Min. | 16 | PP 700 | 423 |
| Professional | | Theo: 8.8 | DFT 35-45 | Turps | | | |
| Gypsum and | | Prac: 5.1 | | (AZH I) | | | |
| Plaster Primer | | | | | | | |
| (PP 700) | | | | | | | |
| 1st Finishing Coat | B, R or S | @ 30 μm | WFT 66- 92 | Water | 2 | PEM 950 | <16 white & |
| Professional | | Theo: 12.7 | DFT 25-35 | | | | tint bases |
| Superior Matt | | Prac: 7 | | | | | tinted |
| (PEM 950/TPM) | | | | | | | |
| 2 nd Finishing Coat | B, R or S | @ 30 μm | WFT 66- 92 | Water | 2 | PEM 950 | <16 white & |
| Professional | | Theo: 12.7 | DFT 25-35 | | | | tint bases |
| Superior Matt | | Prac: 7 | | | | | tinted |
| (PEM 950./TPM) | | | | | | | |



Revision Date: January 2016



SPECIFICATION NO: RD107t

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

^ Spot prime bare and repaired areas with Professional Gypsum and Plaster Primer (PP 700). Allow 16 hours to dry. Finishing Coats

Apply two full coats of Professional Superior Matt (PEM 950/TPM) to achieve complete obliteration, allowing 2 hours drying between coats.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- A B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

