

SPECIFICATION NO: RD126

REPAINT - INTERIOR/EXTERIOR **NEW WORK:**

Masonry (Cement Plaster, Concrete, Off-Shutter, Pre-Cast, Unglazed Brickwork) and Fibre-**SUBSTRATE:**

Cement Board

PAINT FINISH: True colour Thick & Strong PRODUCT CODE: MTC 1/TTM

(Low odour, Acrylic Emulsion for Int/Ext use, Smooth Finish – Waterbased)

COLOUR: Plascon colour range

The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on **ENVIRONMENT:**

the site which will affect the longevity of the coating system

As per ISO 12944-2:1998 Maintenance Cycle (Years)

C1 -Inland 2 C3 -Industrial 2 Coastal / Marine 2 C5 -

Plascon Coating System	Application Method	Spreading Rate	WFT/DFT μm (min & max)	Reducer/ Cleaner	Overcoating time	Technical Data Sheet	TVOC g/&
		m²/ℓ			h @ 23 °C	No	_
Spot Primer	B, R or S	@ 30 μm	WFT 69 -97	Water	2	PSU 1	
Plascon True		Theo: 12	DFT 25-35				
Colour 3-in-1		Prac: 6.6					
Primer Sealer							
Undercoat							
(PSU 1)							
1 st Finishing Coat	B, R or S	@ 25 μm	WFT 95-143	Water	1	MTC	<5 white and
True Colour Thick		Theo: 8.4	DFT 20-30				pastel tinted
& Strong		Prac: 4.5					
(MTC/TTM)							
2 nd Finishing Coat	B, R or S	@ 25 μm	WFT 95-143	Water	1	MTC	<5 white and
True Colour Thick		Theo: 8.4	DFT 20-30				pastel tinted
& Strong		Prac: 4.5					
(MTC/TTM)							



Revision Date: January 2016



SPECIFICATION NO: RD126

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

Spot prime bare and repaired areas with Plascon True colour 3 in 1 Primer Sealer PSU 1, allowing 2 hours to dry.
Finishing Coats

^ Apply two coats of True Colour Thick & Strong (MTC/TTM), to achieve complete obliteration. Allow 1 hour drying time between coats.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- A B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

