

SPECIFICATION NO: RD183t

NEW WORK/REPAINT: REPAINT – INTERIOR

SUBSTRATE: Masonry (Cement Plaster, Concrete, Off-Shutter, Pre-Cast, Unglazed Brickwork) and Fibre-

Cement Board

PAINT FINISH: Plascon Velvaglo Satin PRODUCT CODE: VLO

(Smooth finish – solvent based, premium non-drip satin enamel)

COLOUR: White and standard colours as per colour card, plus Plascon colour system and

other fan decks.

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro climate changes identified on

the site which will affect the longevity of the coating system

As per ISO 12944-2:1998 Maintenance Cycle (Years)

 C1 Inland
 10

 C3 Industrial
 10

 C5 Coastal / Marine
 10

| Plascon Coating | Application | Spreading | WFT/DFT μm | Reducer/ | Overcoating | Technical | TVOC |
|--------------------------------|-------------|-----------|-------------|----------|-------------|------------|--------------|
| System | Method | Rate | (min & max) | Cleaner | time | Data Sheet | g/€ |
| | | m²/ℓ | | | h @ 23 °C | No | |
| Spot Primer | B, R or S | @ 40 μm | WFT 109-129 | Min. | 16 | PP 700 | 423 |
| Professional | | Theo: 8.8 | DFT 35-45 | Turps | | | |
| Gypsum and | | Prac: 5.1 | | (AZH I) | | | |
| Plaster Primer | | | | | | | |
| (PP 700) | | | | | | | |
| 1 st Finishing Coat | B, R or S | @ 30 μm | WFT 56-89 | Min | 16 | VLO | 435 white |
| Plascon Velvaglo | | Theo: 15 | DFT 25-40 | Turps | | | 403 pastel & |
| Satin | | Prac: 8.3 | | (AZH 1) | | | transparent |
| (VLO/TVG) | | | | | | | 409 deep |
| 2 nd Finishing Coat | B, R or S | @ 30 μm | WFT 56-89 | Min | 16 | VLO | 435 white |
| Plascon Velvaglo | | Theo: 15 | DFT 25-40 | Turps | | | 403 pastel & |
| Satin | | Prac: 8.3 | | (AZH 1) | | | transparent |
| (VLO/TVG) | | | | | | | 409 deep |



Revision Date: January 2016



SPECIFICATION NO: RD183t

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

Spot prime bare and repaired areas with Professional Gypsum and Plaster Primer (PP 700). Allow 16 hours to dry.
Finishing Coats

Apply two full coats of Plascon Velvaglo Satin (VLO/TVG) to achieve complete obliteration, allowing 16 hours drying between coats.

NB: if white is used, three coats might be necessary to achieve obliteration.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- A B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

initiative in material particular in the copyright of the initiative in the copyright of th

