

SPECIFICATION SHEET NO: RD424

NEW WORK/REPAINT: REPAINT - EXTERIOR - ROOFS

SUBSTRATE: Chromadek/Factory Coated Sheeting

PAINT FINISH: Crown Roof Paint PRODUCT CODE: CRP

(Superior quality acrylic roof paint)

COLOUR: Standard colours

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on the site which will affect the longevity of the coating system

As per ISO 12944: Maintenance Cycle (Years)

C1 - Inland 4
C3 - Industrial 3
C5 - Coastal / Marine 3

Plascon Coating	Application	Spreading	WFT/DFT	Reducer/	Overcoating	Technical	TVOC
System	Method	Rate	μm	Cleaner	time	Data Sheet	g/€
		m²/€	(min & max)		h @ 23 °C	No	
Spot Primer Coat	B or S	@ 25 μm	WFT 83-125	GP	4	AW 255	618
Plascon Epiwash		Theo: 9.6	DFT 20-30	Ероху	2 weeks		
Strontium		Prac: 5.1		Reducer	max		
Chromate Primer				(EPT 1)			
(AW 255/KAT 508)				Or			
Mixing ratio 1:1				Epiwash			
by volume				Thinner			
				(TH 128)			
1st Finishing Coat	B, R or S	@ 42.5 μm	WFT 140-200	Water	2	CRP	< 20
Crown Roof Paint		Theo: 5.9	DFT 35-50				
(CRP)		Prac: 3.5					
2 nd Finishing Coat	B, R or S	@ 42.5 μm	WFT 140-200	Water	2	CRP	< 20
Crown Roof Paint		Theo: 5.9	DFT 35-50				
(CRP)		Prac: 3.5					



Revision Date: January 2016



SPECIFICATION SHEET NO: RD424

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

Mix base and hardener thoroughly in a 1:1 ratio by volume before use.

^ Spot prime bare and repaired areas with Plascon Epiwash Strontium Chromate Primer (AW 255). Allow minimum 4 hours to dry.

Finishing Coats

Apply two full coats of Crown Roof Paint (CRP) to achieve complete obliteration, allowing 2 hours drying between coats.

TABLE REFERENCES:

Revision Date: January 2016

- Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

