

SPECIFICATION SHEET NO: RD442

NEW WORK/REPAINT: REPAINT - EXTERIOR - ROOFS

SUBSTRATE: Galvanised Iron

PAINT FINISH: Crown Roof Paint PRODUCT CODE: CRP

(Weather resistant acrylic roof coating)

COLOUR: Standard colours

ENVIRONMENT: The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on

the site which will affect the longevity of the coating system

As per ISO 12944: Maintenance Cycle (Years)

 C1 Inland
 4

 C3 Industrial
 3

 C5 Coastal
 3

| Plascon Coating | Application | Spreading | WFT/DFT | Reducer/ | Overcoating | Technical | TVOC |
|--------------------------------|-------------|-----------|-------------|----------|-------------|------------|-----------------|
| System | Method | Rate | μm | Cleaner | time | Data Sheet | g/ & |
| | | m²/€ | (min & max) | | h @ 23 °C | No | |
| Spot Primer Coat | B, R or S | @ 55 μm | WFT 135- | Water | WB topcoat: | EMS 18 | 53.5 |
| Plascon Plascosafe | | Theo: 6.7 | 162 | | 8 | | |
| 18 Primer | | Prac: 4.4 | DFT 50-60 | | SB topcoat: | | |
| (EMS 18) | | | | | 16 | | |
| 1st Finishing Coat | B, R or S | @ 42.5 μm | WFT 140-200 | Water | 2 | CRP | < 20 |
| Crown Roof Paint | | Theo: 5.9 | DFT 35-50 | | | | |
| (CRP) | | Prac: 3.5 | | | | | |
| 2 nd Finishing Coat | B, R or S | @ 42.5 μm | WFT 140-200 | Water | 2 | CRP | < 20 |
| Crown Roof Paint | | Theo: 5.9 | DFT 35-50 | | | | |
| (CRP) | | Prac: 3.5 | | | | | |



Revision Date: January 2016



SPECIFICATION SHEET NO: RD442

SURFACE PREPARATION:

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

APPLICATION:

Primer Coat

^ Spot prime bare and repaired areas with Plascon Plascosafe 18 Primer (EMS 18). Allow 8 hours drying time (water based topcoat) or 16 hours drying time (solvent based topcoat).

Finishing Coats

 Apply two full coats of Crown Roof Paint (CRP) to achieve complete obliteration, allowing 2 hours drying between coats.

TABLE REFERENCES:

Revision Date: January 2016

- ^ Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

