

# SPECIFICATION SHEET NO: RD368

**NEW WORK/REPAINT:** REPAINT – INTERIOR/EXTERIOR

**SUBSTRATE:** Wood

**COLOUR:** 

**PAINT FINISH:** Plascon True Colour Bright Gloss Enamel PRODUCT CODE: GTC

(Smooth finish – solvent based, high gloss)

NOTE: TO TINT USE TSE TINT BASE

White (GTC 1), Black (GTC 2), Cream (GTC 3), Brown (GTC 4) and a deep tint base

**ENVIRONMENT:** The Maintenance Cycle is a guide but can vary due to micro-climate changes identified on

the site which will affect the longevity of the coating system

Maintenance Cycle (Years) As per ISO 12944-2:1998

C1 -Inland 1 C3 -Industrial 1 C5 -Coastal / Marine 1

Plascon Coating	Application	Spreading	WFT/DFT	Reducer/	Overcoating	Technical	TVOC
System	Method	Rate	μm	Cleaner	time	Data Sheet	g/€
		m²/ℓ	(min & max)		h @ 23 °C	No	
Spot Primer	B, R or S	@ 30 μm	WFT 56-78	Min.	16	UC 2	422
Plascon Wood		Theo: 15	DFT 25-35	Turps			
Primer		Prac: 8.3		(AZH 1)			
(UC 2)							
1st Finishing Coat	B, R or S	@ 30 μm	WFT 83-117	Min.	16	TGT	365
Plascon True		Theo: 10	DFT 25-35	Turps			
Colour Bright		Prac: 5.5		(AZH 1)			
Gloss Enamel							
(GTC/TGT 2000)							
2 <sup>nd</sup> Finishing Coat	B, R or S	@ 30 μm	WFT 83-117	Min.	16	TGT	365
Plascon True		Theo: 10	DFT 25-35	Turps			
Colour Bright		Prac: 5.5		(AZH 1)			
Gloss Enamel							
(GTC/TGT 2000)							



Revision Date: September 2016



## SPECIFICATION SHEET NO: RD368

\_\_\_\_\_

#### **SURFACE PREPARATION:**

^ After a full site assessment has been conducted, select the appropriate surface preparation required from Surface Preparation clauses for remedial procedure.

### **APPLICATION:**

#### **Primer Coat**

Spot prime bare and repaired areas with one coat of Plascon Wood Primer (UC 2) to achieve a continuous film. Allow 16 hours to dry.

### **Finishing Coats**

Apply two full coats of Plascon True Colour Bright Gloss Enamel (GTC/TGT 2000)) to achieve complete obliteration, allowing 16 hours drying between coats.

NB: if white is used, three coats might be necessary to achieve obliteration.

\_\_\_\_\_

#### **TABLE REFERENCES:**

Revision Date: September 2016

- Technical Data Sheet (TDS): User must always ensure that latest issue is used.
- B = Brush (ready for use), R = Roller (synthetic, min. 10mm pile) (ready for use), S = Airless spray (ready for use).
- ^ Theoretical spreading rate quoted is for smooth non-porous substrates and does not include allowance for surface profile, porosity, wastage and uneven film application. Suitable allowance should be made according to type of work, method and skill of applicator. Practical spreading rate quoted is an average guide only actual must be determined by user.
- ^ Overcoating times are at 23 °C and 75 % relative humidity. Longer times must be allowed under cooler and moist conditions. DO NOT paint during inclement weather and when temperature is below 10 °C.
- ^ Fading and chalking will occur to a greater or lesser degree depending on pigmentation and generic binder type.
- ^ NB: Life expectancy may vary, depending on environmental conditions and stresses, within the macro/micro climate of the project.

Copyright @Kansai Plascon (Pty) Ltd 2013. All rights reserved. No part of this work may in any form or by any means be reproduced without prior written permission of the copyright owner. PLASCON is the registered trade mark of Kansai Plascon (Pty) Ltd,

\_\_\_\_\_

